

Resistance between the following points shall be checked :

- (1) Terminal B of relay R2(wire No.6) to SH1/2- short circuit
- (2) Terminal A of relay R2(wire No.3) and R1 short circuit
- (3) SH 2/10-R5 (terminal 3 of Board 10) - 27,000 $\pm$ 1500 ohms
- (4) SH3/2A-SH wire No.8) short circuit
- (5) SH1/1-SH(wire No.3) -short circuit

Install the fuses PR2-PR6, the casing RN 10.027 and the measuring unit BI 10 and close the covers of the regulator

Note:(a) while giving the supply the + voltage shall be supplied to the '+' connector contacts through the fuse 10A

(b) Checking is carried out at voltage of 27+IV by removing the measuring unit BI-10 covers and RN-10 027 casing

Checking the voltage of generator in changing speed and load

Repeat the test at SL.No.A2(b)

Checking of frequency of oscillations


Repeat the test at SL No.A2(c)

Checking of voltage of disconnecting circuit operations

Repeat the test at SL.No.A2(d)

CIRCUIT DIAGRAM VR-4

18



A2(d)/
3.4.4

Checking
for voltage
of Disconnecting
circuit operation

Same as in
A2(b) and
Incandescent
lamp 3-4W
28 V

D: Checking for voltage of disconnecting
circuit operation

1. Rig up the circuit as per circuit diagram VE-3. Connect a 28 V, 3-W incandescent lamp between pin No.6 and the negative bus. The resistance of the connecting wires shall not exceed 0.10 Ohm.
Short pin 1 of SH 1 and 7 of SH 2.
Run the generator at a speed of 3650 RPM. Adjust the field rheostat so that a field current of 4.5A to 5.0A is read in the ammeter A1. Increase the speed smoothly till the incandescent lamp burns. At this moment measure the voltage in voltmeter V. Slowly bring the speed of generator to halt. Check whether the protection circuit operates at a generator voltage recorded earlier (usually 29.5 - 33V)


A3/1.2.3.1
to 1.2.2.3
3.1 to
3.4.4
Checking of the
correctness of
electric wiring
and functional
parameters

Multimeter &
plug in 'Jig
with terminal
board' for
easy measure-
ment.

Checking with the help of multimeter is
done as shown below.

Check the following with the help of a
multimeter :-

20
CIRCUIT DIAGRAM VR-3 (For voltage of air connecting circuit)



*Resistance values to be included
 determined in procedure by this since
 as per evaluation sheet*

No. of contacts of Plug Connector	Resistance Value
1. Note take out PR2, PR3, PR5, PR6 fuses	1-4 ohms
2. SH 2/6 - SH2/17	Not more than 15 Ohms.
3. SH2/17-SH2/6	
4. Take out PR4 and insert PR5	
5. SH2/6 SH2/17	1 - 4 Ohms
6. Note take out PR5 insert PR6	
7. SH2/6-SH2/17	1 - 4 Ohms
8. Note: Take out PR6	
9. SH2/4-SH2/7	24 - 33 Ohms
10. SH2/4-SH2/2/6	22-35 Ohms
11. (Note: Insert PR3)	
12. SH2/4-SH2/2	2 - 6 Ohms
13. (Note take out PR3) Insert PR2	
14. SH2/4-SH2/2	2 - 6 Ohms
15. Take out PR2	
16. SH1/2-SH1/1	210 ± 50 Ohms
17. SH1/1-SH1/2	260 ± 100 Ohms
18. SH2/6-SH1/4	230 - 280 Ohms
19. SH2/9-SH2/2	2 - 5 Ohms
20. SH3/1A-SH1/4	230 - 280 Ohms

(b) (i) Supply '+' of Voltage to the SH1/4 Contact and '-' to contact SH 2/8

and

Measure resistance between the following points :-

- (1) SH2/9, SH2/2, SH2/7-SH1/6-1 Ohms (Maximum)
- (11) SH2/9, SH2/4 -----20 Ohms (Maximum)

Disconnect the voltage. Connect + of voltage to SH1/1 and '-' to contact SH2/2. The value of voltage to be measured shall be as under :-

- (1) SH2/7-SH1/5 - 10 to 25 V

Disconnect the voltage and connect '+' of voltage to contact SH2/8 and '-' to contact SH1/2. The readings should not be more than 2 Ohms between the contacts SH2/8 and SH2/7.

Checking of Measuring unit BY-10.

The resistance value between the following points shall be as under :-

- | | |
|-------------------|---------------|
| (1) SH2/5A-SH3/4A | 0 - 110 Ohms |
| (2) SH3/3A-SH3/5B | Short circuit |
| (3) SH2/4A-SH3/4B | Short circuit |
| (4) SH3/4A-SH3/2A | Max. 15 Ohms |
| (5) SH3/2B-SH3/2A | Short circuit |
| (6) SH3/3A-SH3/2A | 2 - 6 Ohms |
| (7) SH3/3B-SH3/3A | Short circuit |
| (8) SH3/1A-SH3/2A | 2 - 6 Ohms |
| (9) SH3/1A-SH3/1B | Short circuit |

1 - 2 - 3 - 4 - 5 - 6 - 7 - 8 - 9 - 10 - 11 - 12 - 13 - 14 - 15 - 16 - 17 - 18 - 19 - 20 - 21 - 22 - 23 - 24 - 25 - 26 - 27 - 28 - 29 - 30 - 31 - 32 - 33 - 34 - 35 - 36 - 37 - 38 - 39 - 40 - 41 - 42 - 43 - 44 - 45 - 46 - 47 - 48 - 49 - 50 - 51 - 52 - 53 - 54 - 55 - 56 - 57 - 58 - 59 - 60 - 61 - 62 - 63 - 64 - 65 - 66 - 67 - 68 - 69 - 70 - 71 - 72 - 73 - 74 - 75 - 76 - 77 - 78 - 79 - 80 - 81 - 82 - 83 - 84 - 85 - 86 - 87 - 88 - 89 - 90 - 91 - 92 - 93 - 94 - 95 - 96 - 97 - 98 - 99 - 100

24/
1.2.4(a)
and
3.5

Testing Megohmmeter
of Insulation 0-500V dc
under normal climatic conditions

IR test is conducted by megohmmeter with 500V DC, short pin No. 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12 and 17 of plug SH-2. Measure the IR between the (a) body and pin No. 1 of SH 1

Between pin 1 to 6 of plug connector SH-1 and electrically not connected circuits :

- SH1/1 - SH1/7
- SH1/2 - SH1/7
- SH1/3 - SH1/7
- SH1/4 - SH1/7
- SH1/5 - SH1/7
- SH1/6 - SH1/7

1
2
3
4
5
AS/1-2.5
and 3.6

Test for Breakdown
Electric test of
Insulation 0.5KV
strength RMS, AC 50HZ
(High voltage test)

Short pin nos.1,2,3,4,5,6,7,8,9,10,11,12
and 17 of connector SH2. Apply a c r.m.s
voltage of 500V, 50Hz for 1 minute between:

- (a) Body and pin No.1 of plug SH1
- (b) -do- 6 of plug SH1
- (c) Electrically non connected circuits
and pin No.1 of plug SH1
- (d) Electrically non connected circuits
and pin No.6 of plug SH1

There shall not be any breakdown or surface
sparks over of insulation.

(Note: 80% of voltage to be applied when
the test is to be repeated at the same
place or elsewhere)

1

2

3

4

5

26

A6/1.2.9 Test for
and 3.7 water
(a) tightness

As explained in
test method

During the acceptance tests, regulator in switched off condition (with the covers closed) is placed into special chamber of volume preferably not less than eight times that of the equipment. Internal cavity of the regulator with the help of special union and rubber tube, is connected with the external medium.

Supply dry air at a pressure of 0.2+0.05 atmosphere inside the chamber for 5 minutes. In this case immediately after the air supply, keep the terminal of the rubber tube coming out of the chamber into a container filled with water, which is kept 2 to 3 cms below the level of the regulator. Regulator is considered to have passed the test provided continuous or periodic release of air bubbles from the outlet end of the tube are not observed.

A7/1.2.6 Interchangeability
and 3.8 check-

1.2.7(a)
3.9(a)

Test for
the effect
of increased voltage

- 1) As in A2
- (b)
- 2) By 24V, 70Ah-4Nos
- 3) Storage oscillator graph

Interchangeability is checked by means of regulating in the disassembled regulator the components and assembly units, from three available at the assembly line. In case no components and assembly units in the assembly line are available, two regulators are disassembled and checked for interchangeability.

Pulses of increased voltage is carried out with generator VG 7500N by four parallelly connected batteries and load of 300A.

Connections are done as shown in circuit diagram VR-4

Pulses of increased voltage upto 70V in 3 microseconds are obtained by means of disconnecting the load 300A at a maximum speed of generator 6500±200 rpm.

Pulses of increased voltage are fed in cycles of 3 pulses in a row in each cycle. No. of cycles is 7. Interval between the cycles is not less than 3 and not more than 10 minutes

Value and duration of pulses are measured by oscillograph.

After the end of the test, the regulator is checked by repeating test at St.No.A2(b)

Short duration switchings of voltage of reverse polarity with value of 30V dc and duration upto 1 minutes

The voltage is fed from a power supply unit. The positive of power supply is fed to pin Nos.2,4,6 and negative to pin No.1 of plug SH1

Repeat Test No A2 (b)
PART IV

This test need not be conducted as the same is conducted vide test No.C7 (Test for heat resistance)
(Cl.No.3.13 of specn)

B2/1.2.7(b) Test for Power
3.9(b) the effect supply
of voltage unit ca-
of reverse pable of
polarity giving
30V dc

Cl/ Insulation
1.2.4(b) resistance
and 3.13 under in-
creased tem-
perature con-
ditions/

Insulation
2.3(c) resistance un-
der increased
and 3.11 humidity

This test need not be conducted as the same is conducted vide test No.C5 (Test for moisture resistance)
(Cl.No.3.11 of specn)